

TITLE 24 - 2013

		Classroom, Lecture Hall, Training Room	Conference, Break Room	Corridor			Open Office (>300 sq. ft.)		Private Office (<300 sq. ft.)		Restroom	Stairwell	Storage Room				
Manual Control	Switch	●	●	●			●		●		●	●	●				
	Dimmer or scene control																
Automatic ON/OFF Control	Timeclock																
	Occupancy sensor	●	●	●			●		●		●	●	●				
	Settings	Full ON	●	●	●			●		●		●	●	●			
		Partial ON															
		Manual ON								●							
		Full OFF	●	●				●		●		●		●			
		Partial OFF			●								●				
Daylight responsive control	●	●	●			●		●		●	●	●					
Receptacle control		● <sub>1</sub>				● <sub>1</sub>		● <sub>1</sub>									
Demand response	● <sub>1</sub>	● <sub>1</sub>	● <sub>1</sub>			● <sub>1</sub>		● <sub>1</sub>		● <sub>1</sub>	● <sub>1</sub>	● <sub>1</sub>					

1 Retrofits do not typically require Demand Response or receptacle control. Demand Response not required for buildings less than 10,000 sq.ft.